



ASSAM POWER GENERATION CORPORATION LIMITED

Registered Office: Bijulee Bhawan, Paltanbazar, Guwahati-781 001, Assam

CIN:U40101AS2003SGC007239

Tel. Fax No.0361-2739522

e-mail:saurav.saikia@apgcl.org, Website: www.apgcl.org

No: APGCL/CGM (H)/W/2013-14/476/Part file/75

Date: 06/05/2025

CORRIGENDUM

E-Tender Notice No. APGCL/CGM (Hydro & Civil)/2025-26/Deep tube well/02(5) dated: 25/04/2025

Name of work: Development, installation and commissioning of 2(two) nos. of deep tubewell including storage tank and filtration unit at Namrup Thermal Power Station (NTPS), APGCL, Namrup, District- Dibrugarh, Assam.

In reference to the Item no.14 of the BOQ for the above E-tender Notice, specification of the items are provided as follows:

Item no.14 of the BOQ:

Supplying, assembling and commissioning of Zincalume steel water storage tank of ISO certified reputed manufacturer with self-supporting Dome roof, heavy duty reinforced PVC Food grade UV stabilized liner, commercial heavy duty external ladder with suitable tank bolt fasteners, nozzle, flanges etc. and all equipment, tools, plants & machineries required for the job, with a standard warranty on all components all complete as per direction of Engineer-in-charge.

Specification of Zincalume water tank:

Capacity of Zincalume water tank = 150 KL (Dia. = 7.95 Mtr. Height = 3.03 Mtr.)

Standard warranty = 5 (Five) years on parts and workmanship.

Warranty for Zincalume Sheet - 30 (Thirty) yrs. against any type of corrosion/rusting and for liner- 20 (Twenty) yrs. respectively.

In reference to the Item no.15 of the BOQ for the above E-tender Notice, warranty clause of the item is provided as follows:

Item no.15 of the BOQ:

Supplying, fitting, assembling and commissioning of water treatment plant with automation to control Iron up to 10 ppm with a capacity of 20 m3 liter per hour plant with all required filter media with backwash automation and main pump automation complete in all respect as specified by Engineer-in-Charge.

Warranty for Water treatment plant:

Standard warranty = 5 (Five) years including pump automation and backwash automation.

AP
06/05/2025

Chief General Manager (Hydro & Civil)
APGCL

C.c. to: -

- 1) The OSD to The Managing Director, APGCL, Bijulee Bhawan, Paltanbazar, Guwahati-781 001, for favour of kind information to The Managing Director, APGCL.
- 2) The DGM (Procurement), APGCL, Bijulee Bhawan, Guwahati-1: for uploading the corrigendum at NIC e-procurement portal (<https://assamtenders.gov.in>)
- 3) The General Manager, NTPS, APGCL, Namrup for information.
- 4) Relevant File.